

## Addendum # 1

Created 01/07/16

### EP 1516-2 Central Avenue Playground Lighting Project

- **Bid Form Revisions:**
  - Fee Proposal Section, Item 2:
    - DELETE: “(Note: required trenching, backfilling of trenches, and excavation of light pole foundation holes to be by others; backfilling of light pole foundation holes to be by contractor)”
    - ADD: “Excavation and Backfilling operations for all light pole foundations to be by contractor in accordance with manufacturer’s specifications.”
  - Fee Proposal Section, Item 4:
    - DELETE: “(Note: required trenching, backfilling of trenches, and excavation of light pole foundation holes to be by others; backfilling of light pole foundation holes to be by contractor)”
    - ADD: “Excavation and Backfilling operations for all light pole foundations to be by contractor in accordance with manufacturer’s specifications.”
- **Project Manual and Technical Specifications Revisions:**
  - Section 16000, Subsection 1.02A(5):
    - DELETE: Subsection 1.02A(5) in its entirety.
    - ADD: new Subsection 1.02A(5): “Excavation and Backfilling operations for all light pole foundations to be by contractor in accordance with manufacturer’s specifications, and all local, state, and federal regulations.”
  - Lighting Manufacturer’s Specifications and Materials: Section 26 56 68 – Exterior Athletic Lighting Specifications:
    - Part 1, subsection 1.5:
      - DELETE Title: “Pre-Bid Submittal Requirements”
      - ADD Title: “Submittal Requirements”
    - Part 1, subsection 1.5A:
      - DELETE: “All substitutions must provide a complete submittal package for approval as outlined in Submittal Information at the end of this section.”
      - ADD: “All substitutions must provide a complete **pre-bid** submittal package for approval as outlined in Submittal Information at the end of this section.”
    - Part 1, subsection 1.5B:
      - DELETE: “The owner/engineer will review **pre-bid** shop drawings from the manufacturers to ensure compliance to the specification.”
      - ADD: “The owner/engineer will review shop drawings from the manufacturers to ensure compliance to the specification.”
    - Part 2, subsection 2.2C:
      - DELETE: “The foundation design shall be based on soil parameters as outlined in the **geotechnical report.**”

- ADD: "The foundation design shall be based on soil parameters as outlined in the Submitted Foundation embedment design"
- **Contract Drawings:**
  - Sheet 1 of 2: Lighting Plan:
    - **Lighting Notes:**
      - DELETE: Note 8: "Excavation for all light post foundations shall be completed by city staff (see sheet 2 for light post foundation design). Contractor shall coordinate with the city of east providence departments of planning and public works to coordinate scheduling as necessary so as to ensure minimal time period of open excavation and a safe and secured project site. Contractor shall set post foundations and backfill in accordance with manufacturer's specifications (see sheet 2 of this plan set)."
      - ADD: Note 8: "Contractor shall excavate foundation post holes, set post foundations, and backfill all light posts in accordance with manufacturer's specifications (see sheet 2 of this plan set)."

BID OPENING remains unchanged as Thursday, January 14, 2016 at 2:00PM